


WAGNER SERVICECENTRUM Co. Ltd., Hlavná 111, 080 01 Prešov



Undersigned representative

of producer : **WAGNER SERVICECENTRUM Co. Ltd., Hlavná 111, 080 01 Prešov**

of workshop: **Teslova 2, 040 12 Košice
Revolučná 59, 044 25 Medzev**

by this proclaims, that the product:

Steel profile for plasterboard profiles, for type, : WAGNER plasterboard profiles CDD 60

is in conformity with clause of the law nr. 90/1998 of digest of laws about the constructional products as amended by the latter acts, if it is mounted in accordance with the technical condition of the product, the manual for the assembly, with declared use of the product and for the product are applied these norms:

STN EN 14195 : 2007 Metal sheets for base constructions of plasterboard systems

Within initial testing of type were certified:

The Characteristics	Declared value or class	Protocol about testing and reference to laboratory
Tolerance of parameters	Profile width $w = 60$ mm Width of flange $w_1 = 26,5$ mm Width of flange $w_2 = 26,5$ mm The angle between web plate and flange $a_1=90$ The angle between web plate and flange $a_2=90$ Flatness $=1,00$ mm	Testing protocol nr. 70-090030 from the day 26.02.2009
Fold of loading	Average values 62/103/320	Testing protocol nr. 70-09-0022 from the day 26.2.2009

Product description:

Parameters: height 27 mm
 width 60 mm

The title and adresses of laboratories, which accomplished tests:

1) TSUS, Studená 3, 821 04 Bratislava, testing workplace Krmanova 5, 040 00 Košice

The producer: **WAGNER SERVICECENTRUM Co. Ltd., Hlavná 111, 080 01 Prešov**

The name: **Róbert Wagner**

Status: **director**

Date: **13.01.2013**

